

July 15, 2011

Director
Division of Water and Waste Management
601 57th Street SE
Charleston, West Virginia 25304-2345
Attention: Permitting

Re: **MOUNT STORM POWER STATION**
NPDES PERMIT NO. WV0005525
DISCHARGE MONITORING REPORT

Dear Director:

Enclosed is the subject Discharge Monitoring Report for the month of June 2011.

This report is required and prepared specifically for the Division of Environmental Protection. It represents truly, accurately, and completely the observed results of measurements and analyses required by the Division to be performed and submitted, but only such results. It is not intended as an assertion of the accuracy of any instrument, reading or analytical result, nor is it an endorsement of the suitability of an analytical or measurement technique.

On June 26, 2011 at approximately 01:15, an estimated 500 gallons of pre-heater wash water reached the Low Volume ponds. The event occurred due to a blocked drain line that prevented the material from draining to the metals waste pond and the water overflowed discharging to the Low Volume ponds. Mary Sanders, WV DEP inspector, was notified of this issue on 06/27/11.

If you or your staff has any questions regarding these reports, please contact me at 304-259-4402.

Sincerely,

K. D. Edwards
Supervisor Environmental
Mt. Storm Power Station

00026594